

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Town of Wellington Water Treatment

Had the following Violations Identified During a Drinking Water Inspection

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on February 7, 2018 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Date Correction is Required	Steps We Are Taking
Failure to Complete an Annual Backflow Report in 2016. (T3)	June 28, 2018	The Town has employed a new Operator in Responsible Charge (ORC). The new ORC will mail out the Backflow Prevention Cross Connection Control Surveys to all non-single family entities. Once these surveys are returned the ORC will review them to determine which entities need to be inspected and if the installation and maintenance of a Backflow Device is needed.
Inadequate Survey Compliance Ratio in 2017. (T2).	June 28, 2018	

What does this mean? What should I do?

- There is nothing you need to do at this time. **There is nothing wrong with your drinking water. These violations are solely clerical in nature.** If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate complete resolution of these items by April 30, 2018. For more information, please contact **Michael J. Carrano** at carranmj@wellingtoncolorado.gov or **970-568-3276**, or **P.O. Box 127 Wellington Colorado 80549**.

This notice is being sent to you by: Town of Wellington Water Treatment - CO135838
Date distributed: **This Public Notice will be mailed out with Water Bills on the week of April 2, 2018.**