



WATER SERVICE LINE PRESSURE TEST
CERTIFICATION

Date: _____ Building Permit # _____

Lot _____ Block _____ Subdivision _____

Address: _____ Wellington, Colorado.
Water Service Address

General Contractor / Builder : _____

State Licensed Plumbing Contractor Name: _____

The water service line is to be pressurized to 100-120 PSI. The service line valves shall be shut and the compressor or pump turned off. The highest pressure achieved shall be maintained for one (1) hour with no observable reduction in pressure.

I certify that the water service line at the address indicated above has been pressure tested in accordance with these requirements and has met the criteria indicated above.

Signature General Contractor

Signature State Licenses Plumbing Contractor

State License Number: _____

PC.-0000000